

	National Oil Corporation of Kenya 1ST ADDENDUM TO THE TENDER FOR SUPPLY, INSTALLATION, COMMISSIONING AND MAINTENANCE OF ABOVE GROUND LPG TANKS AND RELATED LPG PIPING – 19TH JUNE 2017	Ref No. NOCK/PRC/03(1232)
		2016-2017 <hr/> Page 1 of 1

Please refer to tender for **SUPPLY, INSTALLATION, COMMISSIONING AND MAINTENANCE OF ABOVE GROUND LPG TANKS AND RELATED LPG PIPING – Ref No. NOCK/PRC/03(1232)2016-2017** advertised on 6th June 2017.

We hereby issue this 1st addendum giving clarifications to the tender document as below:

No.	Bidder's Query/Clarification Request (quoted as asked)	National Oil Response and/or amendment to the tender
I.	<p>Kindly refer to Pages No 32 & 33 - Section 5.4.2 and Section 5.4.3 of the tender document.</p> <p>The total capacity for 2 MT tank and 1 MT tank is mentioned in the tender as 10000 m3.</p> <p>Please clarify the correct capacities of all the tanks in m3</p>	<p>National Oil clarifies that, the correct specifications/dimensions are as follows;</p> <ul style="list-style-type: none"> • The 5MT tank is 9.5 cubic meters (9.5m3) • The 2MT tank is 3.8 cubic meters (3.8m3) • The 1MT tank is 1.9 cubic meters (1.9m3)

Except as clarified herein, all the other terms and conditions of the tender remain as is and are unchanged.

Ag. CHIEF EXECUTIVE OFFICER